

DUBBO SEWAGE TREATMENT PLANT POINT 2

2021/2022

Licensee: Dubbo Regional Council

EPL No: 3850

Date Sample Taken: 06/06/2022	Date Sample Result Obtained: 07/06/2022			Date Published: 05/08/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	3.08
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.67
	Total Suspended Solids	0 - 30	mg/L	3

Date Sample Taken: 02/05/2022	Date Sample Result Obtained: 03/05/2022			Date Published: 05/08/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	3.33
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	4.02
	Total Suspended Solids	0 - 30	mg/L	2

Date Sample Taken: 19/04/2022	Date Sample Result Obtained: 20/04/2022			Date Published: 05/8/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	2
	Nitrogen (total)	0 - 15	mg/L	2.32
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	4.58
	Total Suspended Solids	0 - 30	mg/L	4

Date Sample Taken: 14/03/2022	Date Sample Result Obtained: 15/03/2022			Date Published: 12/04/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	7
	Nitrogen (total)	0 - 15	mg/L	2.29
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.48
	Total Suspended Solids	0 - 30	mg/L	8

Date Sample Taken: 07/02/2022	Date Sample Result Obtained: 30/03/2022			Date Published: 04/04/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	5
	Nitrogen (total)	0 - 15	mg/L	1.96
	Oil and Grease	0 - 10	mg/L	<10
	Phosphorus	0 - 10	mg/L	3.46
	Total Suspended Solids	0 - 30	mg/L	14

Date Sample Taken: 04/01/2022	Date Sample Result Obtained: 05/01/2022			Date Published: 18/02/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	6
	Nitrogen (total)	0 - 15	mg/L	2.71
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	4.06
	Total Suspended Solids	0 - 30	mg/L	14

Date Sample Taken: 14/12/2021	Date Sample Result Obtained: 05/02/2022			Date Published: 18/02/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	7
	Nitrogen (total)	0 - 15	mg/L	3.25
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.72
	Total Suspended Solids	0 - 30	mg/L	3

Date Sample Taken: 03/11/2021	Date Sample Result Obtained: 04/11/2021			Date Published: 03/02/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	2.31
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.76
	Total Suspended Solids	0 - 30	mg/L	<2

Date Sample Taken: 05/10/2021	Date Sample Result Obtained: 06/10/2021			Date Published: 03/02/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	1.86
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.3
	Total Suspended Solids	0 - 30	mg/L	<2

Date Sample Taken: 08/09/2021	Date Sample Result Obtained: 09/09/2021			Date Published: 22/10/2021
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	2.82
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.36
	Total Suspended Solids	0 - 30	mg/L	2

Date Sample Taken: 10/08/2021	Date Sample Result Obtained: 11/08/2021			Date Published: 07/10/2021
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	1.59
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.08
	Total Suspended Solids	0 - 30	mg/L	<2

Date Sample Taken: 06/07/2021	Date Sample Result Obtained: 07/07/2021			Date Published: 09/08/2021
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	3
	Nitrogen (total)	0 - 15	mg/L	2.66
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.64
	Total Suspended Solids	0 - 30	mg/L	3