

JOHN GILBERT WATER TREATMENT PLANT POINT 1

2019/2020

Licensee: Dubbo Regional Council

EPL No: 11694

Date Sample Taken: 02/06/2020	Date Obtained: 03/06/2020	15/07/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	<2
1		pH	6.5-8.5	mg/L	7.6

Date Sample Taken: 05/05/2020	Date Obtained: 07/05/2020	Date Published: 10/06/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	7.9
1		pH	6.5-8.5	mg/L	4

Date Sample Taken: 07/04/2020	Date Obtained: 09/04/2020	Date Published: 11/05/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	10
1		pH	6.5-8.5	mg/L	7.6

Date Sample Taken: 03/03/2020	Date Obtained: 04/03/2020	Date Published: 6/04/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	6
1		pH	6.5-8.5	mg/L	8

Date Sample Taken: 04/02/2020	Date Obtained: 05/02/2020	Date Published: 12/02/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	6
1		pH	6.5-8.5	mg/L	8.2

Date Sample Taken: 20/01/2020	Date Obtained: 21/01/2020	Date Published: 30/01/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	16
1		pH	6.5-8.5	mg/L	7.9

Date Sample Taken: 03/12/2019	Date Obtained: 04/12/2019	Date Published: 12/12/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	4
1		pH	6.5-8.5	mg/L	8.2

Date Sample Taken: 06/11/2019	Date Obtained: 07/11/2019	Date Published: 19/11/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	4
1		pH	6.5-8.5	mg/L	8.2

Date Sample Taken: 01/10/2019	Date Obtained: 03/10/2019	Date Published: 16/10/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	8
1		pH	6.5-8.5	mg/L	8.1

Date Sample Taken: 3/9/2019	Date Obtained: 17/9/2019	Date Published: 6/11/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	3
1		pH	6.5-8.5	mg/L	8.1

Date Sample Taken: N/A	Date Obtained: N/A	Date Published: 6/11/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	N/A
1		Oil and Grease	0-2	mg/L	N/A
1		Total Suspended Solids	0-15	mg/L	N/A
1		pH	6.5-8.5	mg/L	N/A

Date Sample Taken: 2/7/2019	Date Obtained: 18/7 /2019	Date Published: 12/08/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	5
1		pH	6.5-8.5	mg/L	8