

DUBBO SEWAGE TREATMENT PLANT POINT 2

2023/2024

Licensee: Dubbo Regional Council

EPL No: 3850

Date Sample Taken: 03/04/2024	Date Sample Result Obtained: 14/04/2024			Date Published: 22/04/2024
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	3
	Nitrogen (total)	0 - 15	mg/L	3.27
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.46
	Total Suspended Solids	0 - 30	mg/L	3

Date Sample Taken: 05/03/2024	Date Sample Result Obtained: 18/03/2024			Date Published: 22/04/2024
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	3
	Nitrogen (total)	0 - 15	mg/L	3.29
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	4.3
	Total Suspended Solids	0 - 30	mg/L	20

Date Sample Taken: 06/02/2024	Date Sample Result Obtained: 15/02/2024			Date Published: 22/04/2024
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	5
	Nitrogen (total)	0 - 15	mg/L	2.75
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.78
	Total Suspended Solids	0 - 30	mg/L	6

Date Sample Taken: 03/01/2024	Date Sample Result Obtained: 16/01/2024			Date Published: 16/2/2024
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	2.31
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	4.98
	Total Suspended Solids	0 - 30	mg/L	8

Date Sample Taken: 06/12/2023	Date Sample Result Obtained: 22/12/2023			Date Published: 29/01/2024
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	1.67
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	5.06
	Total Suspended Solids	0 - 30	mg/L	4

Date Sample Taken: 08/11/2023	Date Sample Result Obtained: 20/11/2023			Date Published: 29/1/2024
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	2
	Nitrogen (total)	0 - 15	mg/L	1.69
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.48
	Total Suspended Solids	0 - 30	mg/L	8

Date Sample Taken: 10/10/2023	Date Sample Result Obtained: 19/10/2023			Date Published: 21/11/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	4
	Nitrogen (total)	0 - 15	mg/L	1.56
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.14
	Total Suspended Solids	0 - 30	mg/L	7

Date Sample Taken: 05/09/2023	Date Sample Result Obtained: 13/09/2023			Date Published: 12/10/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	2.93
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.74
	Total Suspended Solids	0 - 30	mg/L	3

Date Sample Taken: 01/08/2023	Date Sample Result Obtained: 10/08/2023			Date Published: 12/10/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	4.23
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	4.34
	Total Suspended Solids	0 - 30	mg/L	2

Date Sample Taken: 04/07/2023	Date Sample Result Obtained: 13/07/2023			Date Published: 21/08/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	5.27
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	4.82
	Total Suspended Solids	0 - 30	mg/L	2