

JOHN GILBERT WATER TREATMENT PLANT POINT 1

2020/2021

Licensee: Dubbo Regional Council

EPL No: 11694

Date Sample Taken: 01/06/2021	Date Obtained: 02/06/2021	Date Published 8/07/2021	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	<2
1		pH	6.5-8.5	mg/L	8

Date Sample Taken: 11/05/2021	Date Obtained: 12/05/2021	Date Published 15/06/2021	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	4
1		pH	6.5-8.5	mg/L	8

Date Sample Taken: 14/04/2021	Date Obtained: 15/04/2021	Date Published 11/05/2021	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	<2
1		pH	6.5-8.5	mg/L	7.9

Date Sample Taken: 02/03/2021	Date Obtained: 03/03/2021	Date Published 13/04/2021	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	8
1		pH	6.5-8.5	mg/L	8.1

Date Sample Taken: 02/02/2021	Date Obtained: 03/02/2021	Date Published 10/03/2021	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	10
1		pH	6.5-8.5	mg/L	8.5

Date Sample Taken: 05/01/2021	Date Obtained: 07/01/2021	Date Published 11/02/2021	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	8
1		pH	6.5-8.5	mg/L	8.1

Date Sample Taken: 01/12/2020	Date Obtained: 02/12/2020	Date Published 13/01/2021	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	6
1		pH	6.5-8.5	mg/L	7.8

Date Sample Taken: 03/11/2020	Date Obtained: 04/11/2020	Date Published 11/12/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	N/A
1		pH	6.5-8.5	mg/L	7.7

Date Sample Taken: 06/10/2020	Date Obtained: 07/10/2020	Date Published 09/11/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	N/A
1		pH	6.5-8.5	mg/L	7.5

Date Sample Taken: 01/09/2020	Date Obtained: 02/09/2020	Date Published 22/10/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	N/A
1		pH	6.5-8.5	mg/L	7.7

Date Sample Taken: N/A	Date Obtained: N/A	Date Published: 09/09/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	N/A
1		Oil and Grease	0-2	mg/L	N/A
1		Total Suspended Solids	0-15	mg/L	N/A
1		pH	6.5-8.5	mg/L	N/A

Date Sample Taken: 07/07/2020	Date Obtained: 08/07/2020	Date Published 10/08/2020	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	N/A
1		pH	6.5-8.5	mg/L	7.7