

JOHN GILBERT WATER TREATMENT PLANT POINT 1

2017/2018

Date Sample Taken: 05/06/2018		Date Obtained: 18/06/2018		Date Published: 11/07/2018		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2		
1		Oil and Grease	0-2	mg/L	<1		
1		Total Suspended Solids	0-15	mg/L	2		
1		pH	6.5-8.5	mg/L	8.1		

Date Sample Taken: 01/05/2018		Date Obtained: 15/05/2018		Date Published: 07/06/2018		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2		
1		Oil and Grease	0-2	mg/L	<1		
1		Total Suspended Solids	0-15	mg/L	7		
1		pH	6.5-8.5	mg/L	8.2		

Date Sample Taken: 10/04/2018		Date Obtained: 30/04/2018		Date Published: 09/05/2018		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	< 2		
1		Oil and Grease	0-2	mg/L	< 1		
1		Total Suspended Solids	0-15	mg/L	4		
1		pH	6.5-8.5	mg/L	8.2		

Date Sample Taken: 06/03/2018		Date Obtained: 29/03/2018		Date Published: 05/04/2018		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	< 2		
1		Oil and Grease	0-2	mg/L	< 1		
1		Total Suspended Solids	0-15	mg/L	7		
1		pH	6.5-8.5	mg/L	8.1		

Date Sample Taken: 06/02/2018		Date Obtained: 23/02/2018		Date Published: 26/02/2018		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	< 2		
1		Oil and Grease	0-2	mg/L	< 1		
1		Total Suspended Solids	0-15	mg/L	6		
1		pH	6.5-8.5	mg/L	7.8		

Date Sample Taken: 09/01/2018		Date Obtained: 23/01/2018		Date Published: 12/02/2018		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	< 2		
1		Oil and Grease	0-2	mg/L	< 1		
1		Total Suspended Solids	0-15	mg/L			
1		pH	6.5-8.5	mg/L	8.2		

Date Sample Taken: 05/12/2017		Date Obtained: 19/12/2017		Date Published: 21/12/2017		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	< 2		
1		Oil and Grease	0-2	mg/L	< 1		
1		Total Suspended Solids	0-15	mg/L			
1		pH	6.5-8.5	mg/L	8.1		

Date Sample Taken: 07/11/2017		Date Obtained: 17/11/2017		Date Published: 20/12/2017		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	< 2		
1		Oil and Grease	0-2	mg/L	< 1		
1		Total Suspended Solids	0-15	mg/L			
1		pH	6.5-8.5	mg/L	7.9		

Date Sample Taken: 10/10/2017		Date Obtained: 23/10/2017		Date Published: 13/11/2017		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	< 2		
1		Oil and Grease	0-2	mg/L	< 1		
1		Total Suspended Solids	0-15	mg/L			
1		pH	6.5-8.5	mg/L	8		

Date Sample Taken: 05/09/2017		Date Obtained: 19/09/2017		Date Published: 19/10/2017		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	< 2		
1		Oil and Grease	0-2	mg/L	< 1		
1		Total Suspended Solids	0-15	mg/L			
1		pH	6.5-8.5	mg/L	8.2		

Date Sample Taken: 15/08/2017		Date Obtained: 25/08/2017		Date Published: 03/10/2017		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	< 2		
1		Oil and Grease	0-2	mg/L	< 1		
1		Total Suspended Solids	0-15	mg/L	5		
1		pH	6.5-8.5	mg/L	8.2		

Date Sample Taken: 04/07/2017		Date Obtained: 18/07/2017		Date Published: 09/08/2017		Licence Number: 11694	
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result		
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	1		
1		Oil and Grease	0-2	mg/L	0.5		
1		Total Suspended Solids	0-15	mg/L	16		
1		pH	6.5-8.5	mg/L	8.2		