

JOHN GILBERT WATER TREATMENT PLANT POINT 1

2018/2019

Licensee: Dubbo Regional Council

EPL No: 11694

Date Sample Taken: 4/6/2019	Date Obtained: 17/06 /2019	Date Published: 16/07/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	3
1		pH	6.5-8.5	mg/L	8.2

Date Sample Taken: 14/05/2019	Date Obtained: 27/05 /2019	Date Published: 13/06/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	12
1		pH	6.5-8.5	mg/L	7.9

Date Sample Taken: 16/4/2019	Date Obtained: 16/5 /2019	Date Published: 17/5/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	8
1		pH	6.5-8.5	mg/L	8

Date Sample Taken: 05/3/2019	Date Obtained: 19/3/2019	Date Published: 10/4/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	480
1		pH	6.5-8.5	mg/L	8.1

Date Sample Taken: 05/2/2019	Date Obtained: 20/2/2019	Date Published: 14/3/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	7
1		pH	6.5-8.5	mg/L	8.2

Date Sample Taken: 08/1/2019	Date Obtained: 19/1/2019	Date Published: 12/2/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	7
1		pH	6.5-8.5	mg/L	8.2

Date Sample Taken: 04/12/2018	Date Obtained: 21/12/2018	Date Published: 18/1/2019	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	13
1		pH	6.5-8.5	mg/L	8.3

Date Sample Taken: 06/11/2018	Date Obtained: 15/11/2018	Date Published 11/12/2018	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	9
1		pH	6.5-8.5	mg/L	8.2

Date Sample Taken: 09/10/2018	Date Obtained: 18/10/2018	Date Published: 08/11/2018	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	8
1		pH	6.5-8.5	mg/L	8.1

Date Sample: September 2018	Date Obtained:	Date Published:	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	N/A
1		Oil and Grease	0-2	mg/L	N/A
1		Total Suspended Solids	0-15	mg/L	N/A
1		pH	6.5-8.5	mg/L	N/A

Date Sample Taken: 14/08/2018	Date Obtained: 23/08/2018	Date Published: 07/11/2018	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	4
1		pH	6.5-8.5	mg/L	8.2

Date Sample Taken: 03/07/2018	Date Obtained: 11/08/2018	Date Published: 27/08/2018	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	2
1		pH	6.5-8.5	mg/L	8.1