

# JOHN GILBERT WATER TREATMENT PLANT POINT 1

## 2021/2022

Licensee: Dubbo Regional Council

EPL No: 11694

Date Sample Taken: 06/06/2022	Date Obtained: 07/06/2022	Date Published: 05/08/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<3
1		Total Suspended Solids	0-15	mg/L	3
1		pH	6.5-8.5	mg/L	7.9

Date Sample Taken: 02/05/2022	Date Obtained: 03/05/2022	Date Published: 05/08/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<3
1		Total Suspended Solids	0-15	mg/L	10
1		pH	6.5-8.5	mg/L	7.6

Date Sample Taken: 19/04/2022	Date Obtained: 20/04/2022	Date Published: 05/08/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<3
1		Total Suspended Solids	0-15	mg/L	5
1		pH	6.5-8.5	mg/L	7.9

Date Sample Taken: 01/03/2022	Date Obtained: 02/03/2022	Date Published: 12/04/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	5
1		pH	6.5-8.5	mg/L	8.5

Date Sample Taken: 08/02/2022	Date Obtained: 30/03/2022	Date Published 04/04/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	5
1		pH	6.5-8.5	mg/L	8.5

Date Sample Taken: 04/01/2022	Date Obtained: 05/02/2022	Date Published 18/02/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	5
1		pH	6.5-8.5	mg/L	8.4

Date Sample Taken: 14/12/2021	Date Obtained: 05/02/2022	Date Published 18/02/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	7
1		pH	6.5-8.5	mg/L	8.4

Date Sample Taken: 03/11/2021	Date Obtained: 04/11/2021	Date Published 03/02/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	1
1		Oil and Grease	0-2	mg/L	0.5
1		Total Suspended Solids	0-15	mg/L	3
1		pH	6.5-8.5	mg/L	8

Date Sample Taken: 05/10/2021	Date Obtained: 06/10/2021	Date Published 03/02/20212	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	3
1		pH	6.5-8.5	mg/L	8

Date Sample Taken: 30/08/2021	Date Obtained: 31/08/2021	Date Published 21/10/2021	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	<2
1		pH	6.5-8.5	mg/L	7.9

Date Sample Taken: 10/08/2021	Date Obtained: 11/08/2021	Date Published 07/10/2021	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	8
1		pH	6.5-8.5	mg/L	7.7

Date Sample Taken: 06/07/2021	Date Obtained: 07/07/2021	Date Published 09/08/2021	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	3
1		pH	6.5-8.5	mg/L	8